

NTPC LTD

CC-OS

EOC NOIDA

Sub: Qualifying Requirement for Vendor Enlistment for supply of Tube Nest of Oil Coolers (Except MOT, Seal Oil & Control Fluid System)

A)	MEG DETAILS		
	1.0	MEG NO.	50MEC-03(B)
	2.0	MEG DESCRIPTION	Tube Nest of Oil Coolers (Except MOT, Seal Oil & Control Fluid System)
	3.0	RESPONSIBILITY CENTRE	ER-II
B)	Technical Criteria of QR: 1. The applicant should be a manufacturer of Oil Coolers/ Tubular Heat Exchangers. 2. The applicant should have supplied at least (8) Tube Nests/Complete Oil Coolers for any of the following equipments; ID Fan/FD Fan/PA Fan/ MD BFP/TDBFP/ MOT/Seal Oil system for any Thermal Plant having unit capacity 200 MW or above in INDIA (Directly to NTPC, or, as an OEM to package supplier) during the last 5 years reckoned as on date of submission of application. 3. "Bidder has to give their willingness to stand guarantee for the product for 36 months from date of supply or 30 months from date of installation whichever is earlier"		
C)	Other Documents to be submitted: In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the Applicants applying for enlistment:- 1. Three POs of the highest executed values of similar work during previous five years from the date of application. Copy of Invoice / Completion certificate from the concerned buyer/s in support of successful execution of supply against the POs to be submitted. 2. Audited balance sheet including Profit & Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted. 3. Latest annual report OR NSIC / SSI / MSME registration certificate / BIS license / ISO certificate / Certificate of registration from the concerned excise department / any other statutory document as a proof of being manufacturer of the required material. 4. Any other documents in addition to the above which the applicant wants to submit.		
D)	NOTE-1	Similar works means: Supply of Tube Nest / Oil Coolers / Tubular Heat Exchangers to any Thermal Power Plant of minimum unit capacity 60MW	
	NOTE-2	The executed value means Basic value of quantity of similar works executed/supplied against the reference PO(also applicable to partly executed POs as on date of application).Where PO value is composite(i.e. including Taxes etc.),the applicant to give item-wise break-up of Composite PO value mentioning Basic Value, Taxes etc.	

NTPC LTD
CC-OS
EOC NOIDA

Sub: Technical Specifications for Vendor Enlistment for supply of Tube Nest of Oil Coolers (Except MOT, Seal Oil & Control Fluid System)

A)	MEG DETAILS		
	1.0	MEG NO.	50MEC-03(B)
	2.0	MEG DESCRIPTION	Tube Nest of Oil Coolers (Except MOT, Seal Oil & Control Fluid System)
	3.0	RESPONSIBILITY CENTRE	ER-II
B)	Technical Specifications: 1. Manufacturing & Supply of Tube Nest shall be as per the given details in the Tender. 2. Tubes shall be of Cupro-Nickel/ Admiralty Brass or other MOC (Material of Construction) as per requirement. 3. Tube Nest Assembly may consist of TUBES, TUBE PLATES, FLANGE, BAFFLES and other required components, if any. 4. Vendor will procure Tubes from NTPC approved Tube manufacturer's only. Tubes will be inspected at Tube manufacturer's works as per NTPC approved Quality Plan. 5. Vendor will manufacture and supply Tube Nest Assembly as per NTPC APPROVED QP for that particular enquiry.		